H.O.: 04, Wood Wala Corporation, Plot No 10, Sec. 24, Near Blue Dart, Turbhe, Navi Mumbai : 400705. WhatsApp: 9322046784
 E-mail: infosbfire@gmail.com
 Web.: www.sbfire.co.in

Service Available In: Mumbai | Pune | Aurangabad

Ref: SB/57

P.P. EQUIPMENT

License No. MFS / LA / RF-117 / RD-112

FORM 'B'

See Section 3(3) And Rule 4(2)

Six Monthly Certificates to be given in every January and July by the Owner or the Occupier for compliance of the Fire Prevention and Life Safety Measures.

CERTIFICATES

Certified that we have carried out inspection of the Fire Prevention and life safety measure installed in the following Building or premise namely:

> M/S: SHREERAM SHIKSAN SANSTHA'S PHOENIX INTERNATIONAL & THE LILLIPUTS AT: PLOT NO 32, 33 SEC.3, AIROLI, NAVI MUMBAI.

We Further certify that these installations in the above-mentioned building are maintained in good repair and efficient conditions during the period from JULY 2024 TO DECEMBER 2024 as required under the Provision of the Maharashtra Fire Prevention and Life Safety measures Act 2006 (Mah.III of 2007) The details of the inspection of installations carried by us are mentioned in the report appended herewith.

> Balasaheb Ramprasad Budhawant Date: 2025,01.06
> Budhawant 10:31:53 +05'30'

NAVI MUMBA

93220 46784 / 84229 29280

PLACE: NAVI MUMBAI

Signature and Address of the licensed Agency

Date: 06/01/2025

प्रमाणपत्र दाखल करून घेण्यात आले अग्निशमन विभाग महानगरपालिका

AUTHORIZED DEALER


















+91 80979 18777 / 84229 29283 93220 46784 / 84229 29280

H.O.: 04, Wood Wala Corporation, Plot No 10, Sec.24, Near Blue Dart, Turbhe, Navi Mumbai : 400705.

• WhatsApp: 9322046784 • E-mail: infosbfire@gmail.com • Web.: www.sbfire.co.in

Service Available In: Mumbai | Pune | Aurangabad

Date: 06/01/2025

ANNEXURE - I

Ref: SB/57

License No. MFS / LA / RF-117 / RD-112

M/S: SHREERAM SHIKSAN SANSTHA'S PHOENIX INTERNATIONAL & THE LILLIPUT'S AT: PLOT NO 32, 33 SEC.3, AIROLI, NAVI MUMBAI.

SR.NO	EQUIPMENTS DETAILS	QUANTITY
1.	Down Comer/ Wet Riser 4"	01 NOS
2.	Hose Reel with shut off nozzle	07 NOS
3.	Landing Hydrant Valve	13 NOS
4.	Hose Box	11 NOS
5.	Canvas Hose Pipe	11 NOS
6.	Sprinkler	Each Floor
7.	Branch Pipe Nozzle	11 NOS
8.	Under Ground water tank for firefighting 50000 ltr	01 NOS
9.	Over headwater tank for firefighting 20000 ltr	01 NOS
10.	Firefighting Main Pump (submersible)	01 NOS
11.	Firefighting Main standby Pump (submersible)	01 NOS
12.	Firefighting Jockey Pump (submersible)	01 NOS
13.	Firefighting Booster Pump	01 NOS
14.	Siamese inlet	01 NOS
15.	Over Head water tank	01 NOS
16.	ABC Type Fire Extinguisher 1 kg	01 NOS
17.	ABC Type Fire Extinguisher 2 kg	03 NOS
18.	ABC Type Fire Extinguisher 5 kg	28 NOS
19.	CO2 Type Fire Extinguisher 3 kg	05 NOS
20.	Control panel	01 NOS
21.	Fire alarm panel	02 NOS
22.	MCP	14 NOS
23.	Hooter	14 NOS

Balasaheb Digitally signed by Ramprasad Ramprasad Budhawant Date: 2025.01.06 10:32:46+05'30'



















Govt. of Maharashtra Directorate of Maharashtra Fire Service

Vidyanagri, Hans Bhugra Marg, Santacruz (East), Mumbai - 400 098, Tel-022-26677555, Fax-022-26677666 www.mahafireservice.gov.in

FORM N

[(See section 9 (3) and rule 14] License to act as a License Agency for the purpose of Fire Prevention and Life Safety Measure

License No. MFS / LA / RF-117 / RD-112

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to M/s. S B Fire Safety Services having their registration office at A1 88 Shop No. 2, Sec-21, Turbhe, Navi Mumbai 400705 and their contact details are Office Number: 8097918777 and Email ID: infosbfire@gmail.com with PAN registration No. APUPB6536K and GST No. 27APUPB6536K1ZD to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

1. Fire Fighting and Sprinkler System:

Class D

2. Detection and Fire Suppression System:

Class D

M/s. S B Fire Safety Services shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from 19.02.2024 to 18.02.2026

Kiran

Hatyal Digitally signed by Hatyal Kiran Date: 2024.02.22

Asst Director

Balasaheb Balasaheb Digitally signed by Ramprasad Budhawant Budhawant Date: 2024.02.21 09:44:20 +05:30'

MUMBA

Santosh Digitally signed by Santosh Warick Date: 2024.02.22 Warick 23:32:07 +05'30'

(SS Warick) Director Maharashtra Fire Service

Date: 19.02.2024

Digital Signature of Authorized Person to sign Form A or Form B

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.