

	नवी मुंबई महानगरपालिका अग्निशमन विभाग सेक्टर-16अ, वाशी, नवी मुंबई, 400703 दूरध्वनी क्र: वाशी-022-27660101,101 सीबीडी-022-2457211,102 ऐरोली-022-27796600 नेरुळ - 022-27707101	Navi Mumbai Municipal Corporation Fire Brigade Department Sector -16A,Vashi,Navi Mumbai - 400703 Tel No. Vashi - 022-27660101,101 CBD - 022-27572111,102 Airoli - 022- 27796600 Nerul – 022-27707101
---	---	--

No.NMMC /Fire/HQ/Vashi/ 877 /2026
Date:-30/07/2026

To,
Ms. Shreeram Shikshan Sanstha's
Phoenix Public School
Plot No.32, Sector-03
Airoli, Navi Mumbai.

Sub:- submission of "B" form certificate

Ref:- 1. Your online application vide no. REN/Fire/B/Oth/2026/15559 dtd 20/07/2026.
2. Form "B" certificate submitted by License Agency M/s Bright Enterprises.
3. Site inspection report of Station Officer Airoli on dated 23/07/2026

Dear Sir,

With reference to above subject certified that M/s. Shreeram Shikshan Sanstha's Phoenix Public School on plot no.32 sector 03 Airoli Navi Mumbai having Ground Floor + 7 upper floors have completed with fire prevention and fire safety requirement in accordance with the rules of Fire services and verified by the Officer's concerned of fire service on dated 23/07/2026 in presence of school concern person and that the building / premises is fit for occupancy with rule and subject to compliance of specific condition as appended.

Issued on dated 30/07/2025 at Vashi Navi Mumbai.

M/s Bright Enterprises submitted the form "B" certificate on dated 16/07/2026 (License no. MFS/LA/F-251 / D-243). At the time of inspection fire fighting system installed in the school building found in good working condition.



Divisional Fire Officer
Navi Mumbai Municipal Corporation



BRIGHT

Enterprises

Fire Equipment Sales, Insatallation & Servicing, Signage & many more.

Shop No.1, Plot No.11
Near Platinum Inn Hotel, Sector- 19C
vashi, Navi Mumbai - 400705.
8879523644 / 9892976434
brightenterprises410@gmail.com

Ref No:BE/45/2026

FORM B

[See section 3(3) and rule 4(2)]

Six monthly certificate to be given in every January and July by the occupier for Compliance of the prevention and life safety Measures.

CERTIFICATE

Certify that I/We have carried out inspection of the fire Prevention the life measures installed In the following Building Premises namely:-

**M/S. SHREERAM SHIKSHAN SANSTHA'S
"PHOENIX PUBLIC SCHOOL"
AT: PLOT NO. 32, SEC.03, AIROLI, NAVI MUMBAI**

I/We further certify that these installation in the above mentioned building are maintained in Good repair and efficient condition during the period 1st January 2026 to 30th June 2026 As required Under the provision of the Maharashtra Fire Prevention and Life Measures act 2006 (Mah. III of 2007). The details of the inspection carried out by me/us are Mentioned in the report appended here with.

Place: Vashi- (Navi Mumbai)

Date: -16.07.2026

License No:-

MFS/LA/F-251/D-243

જાતી/877/2026

दिनांक 30/07/2026

‘ब’ प्रमाणपत्र दाखल करून घेण्यात आले

अग्निशमन विभाग

नवी मुंबई महानगरपालिका

Prabhakar Digitally signed
by Prabhakar
r Hiranman Hiranman Gadhe
Gadhe Date: 2026.07.30
13:46:18 +05'30'
Signature of Licensed Agency

Fire Equipment Sales, Insatallation & Servicing, Signage & many more.

ANNEXURE-I

Ref: BE/45/2026

Date:16.07.2026

License No: - MFS/LA/F-251/D-243

**M/S. SHREERAM SHIKSHAN SANSTHA'S
"PHOENIX PUBLIC SCHOOL"**

AT: PLOT NO. 32, SEC.03, AIROLI, NAVI MUMBAI

Sub: - Details of work and related activities, which we have performed are mentioned as appended below:

Sr. No.	Equipment Details	Qty.
1	Down Comer cum Wet Riser	0 No.
2	Single Head Landing valve	07 Nos.
3	Hose reel hose with shut off nozzle	07 Nos.
4	Single Door Metal Hose Box	11 Nos.
5	RRL Type Canvas hose	11 Nos.
6	Branch Pipe	11 Nos.
7	Over Head Tank for Fire Fighting	01 No.
8	Electric Booster Pump	01 No.
9	Under Ground Tank for Fire Fighting	01 No.
10	Fire Fighting Electric Main Pump	01 No.
11	Fire Fighting Electric Sprinkler Pump	01 No.
12	Fire Fighting Jockey Pump	01 No.
13	Sprinkler System (Lift Lobby/Common Corridor)	Yes
14	Courtyard Hydrant Valve	06 Nos.
15	Alarm Panel	02 No.
16	MCP cum Hooter	14 Nos.
17	Smoke Detector (Lift Machine Room/ Meter Room)	Yes
18	Fire Sand Bucket	06 Nos.
19	Four Way Siamese Connection	01 No.
20	ABC Type Fire Extinguisher 1kgs	01 No.
21	ABC Type Fire Extinguisher 2kgs	03 Nos.
22	ABC Type Fire Extinguisher 5kgs	28 Nos.
23	CO2 Type Fire Extinguisher 3kgs	05 Nos.

Prabhaka Digitally signed
by **Prabhakar**
r Hiranman Hiranman Gadhe
Gadhe Date: 2026.07.30
13:46:35 +05'30'

For:-BRIGHT ENTERPRISES



**Govt. of Maharashtra
Directorate of Maharashtra Fire & Emergency Services**

Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-69820595, Fax-022-26677666
www.mahafireservice.gov.in

FORM N

[(See section 9 (3) and rule 14]

**License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure**

License No. MFS / LA / F-251 / D- 243

Date: 17.11.2025

License is hereby granted under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. Ill of 2007) to **M/s. Bright Enterprises** having their registered office at **238, Plot No. 14b, Grohiam Bldg, Sector 19, Vashi, Navi Mumbai-400705** and their contact details are Office Number: **9892976434** and Email ID: **dharmeshthakker77712@gmail.com** with PAN registration No. **ACJPT9206C** and GST No. **27ACJPT9206C1ZH** to act as a Licensed Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

- | | |
|---|---------|
| 1. Fire Fighting and Sprinkler System: | Class D |
| 2. Detection and Fire Suppression System: | Class D |

M/s. Bright Enterprises shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **17.11.2025 to 16.11.2027**

SANTOSH
SHRIDHAR
WARICK
Digitally signed by
SANTOSH SHRIDHAR
WARICK
Date: 2025.12.03
22:02:23 +05'30'

(S S Warick)
Director
MF&ES, Mumbai

License Agency Digital Sign
Prabhakar
Digitally signed by
Prabhakar
Hiraman Gadhe
Date: 2025.12.03
14:43:17 +05'30'

Note:
* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.